

RATINGS

Type	Adjustable Range [bar]	Max. Static Pressure [bar]	Electrical Supply
PPL	30 ÷ 350	600	3A / 250 V ac
PML	0.5 ÷ 100	300	3A / 250 V ac
PMC	0.15 ÷ 80	30 ÷ 150	3A / 250 V ac
PPC	30 ÷ 300	600	3A / 250 V ac
PPCF	30 ÷ 300	600	3A / 250 V ac
PSM	0.2 ÷ 100	80 ÷ 300	6A / 250 V ac
PSP	30 ÷ 300	300 ÷ 600	6A / 250 V ac

Type	Adjustable Range [mbar]	Max. Static Pressure [bar]	Electrical Supply
VSM	-100 ÷ -900	20	6A / 250 V ac

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No.03/00058(E3) and its supplementary Type Approval Terms and Conditions form part of this Certificate.

All other details remain as the previous Certificate No. 03/00058(E2) to which this new Certificate should be attached.

Certificate No. 03/00058(E3)
Issue Date 10 August 2017
Expiry Date 12 June 2022
Sheet 2 of 2



Lloyd's Register EMEA
 Southampton Boldrwood Innovation Campus, Burgess Road, Southampton SO16 7QF

Trieste Technical Support Office
 Lloyd's Register EMEA

Lloyd's Register EMEA
 is a subsidiary of Lloyd's Register Group